

Addendum 2 - SBCUSD Security Alarm Upgrade Phase 1, Sep. 2014, site list

		CODE	SITE		FACP	FACP TYPE	FACP LOCATION	SCN #	# of Module
1	ES	724	ALLRED		SIMPLEX 4010	ADDRESSABLE	ADMIN. OFFICE	3	18
			303 South K St, 92410						
2	ES	120	DAVIDSON		SIMPLEX 4002	NON ADDRESSABLE	ADMIN. OFFICE	3	35
			2844 Davidson Ave, 92405						
3	ES	130	HILLSIDE		EDWARDS EST	ADDRESSABLE	ADMIN. OFFICE	2	45
			4975 N. Mayfield Ave., 92407						
4	ES	138	KIMBARK		SIMPLEX 4010	ADDRESSABLE	ADMIN. CUST. RM.	3	28
			18021 W. Kenwood Ave., 92407						
5	ES	142	LINCOLN		EDWARDS EST	ADDRESSABLE	ADMIN. ELEC RM	1	29
			255 W. 13th St., 92405						
6	ES	164	PALM		SIMPLEX 4020	ADDRESSABLE	ADMIN. PWR. RM.	3	49
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			6565 Palm Ave., 92407						
7	ES	168	RILEY		EDWARDS EST	ADDRESSABLE	ADMIN. CUST. RM.	2	39
			1266 N. G St., 92405						
8	ES	172	ROBERTS		SIMPLEX 4020	ADDRESSABLE	ADMIN. PWR. RM.	3	43
			494 E. 9th St., 92410						
9	MS	302	ARROWVIEW		EDWARDS EST-3	ADDRESSABLE	ADMIN. MDF RM.	2	93
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			2299 N. G St., 92405						
10	MS	306	DEL VALLEJO		EDWARDS EST-3	ADDRESSABLE	ADMIN. OFFICE	2	92
				Sub. Pnl.	SIMPLEX 4002	NON ADDRESSABLE	ADMIN. OFFICE		
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			1885 e. Lynwood Dr., 92404						
11	MS	310	KING		SIMPLEX 4100U	ADDRESSABLE	ADMIN. MDF RM.	3	68
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			1250 Medical Center Dr., 92411						
12	MS	316	SHANDIN HILLS		EDWARDS EST-3	ADDRESSABLE	ADMIN. OFFICE	2	30
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			4301 Little Mountain Dr., 92407						
13	MS	318	CESAR CHAVEZ		SIMPLEX 4100U	ADDRESSABLE	ADMIN.MDF RM	3	57
			6650 N. Magnolia Ave., 92407						
14	HS	410	ARROYO VALLEY		SIMPLEX 4100	ADDRESSABLE	ADMIN. OFFICE	3	192
					11 NODE NET.				
					One node (Simplex 4100) per Bldg. In signal Rm.				
			1881 W. Base Line St., 92411						
15	HS	402	CAJON		HONEYWELL E3	ADDRESSABLE	ADMIN. OFFICE	3	154
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			1200 W. Hill Dr., 92407						

		CODE	SITE		FACP	FACP TYPE	FACP LOCATION	SCN #	# of Module
16	HS	404	PACIFIC		EDWARDS EST	ADDRESSABLE	ADMIN. OFFICE	2	136
					EDWARDS EST	ADDRESSABLE	AUDITORIUM		
					EDWARDS EST	ADDRESSABLE	GYM		
			1020 Pacific St., 92404						
17	HS	408	SAN GORGONIO		EDWARDS EST	ADDRESSABLE	ADMIN. ELEC RM.	2	201
				Sub. Pnl.	NOTIFIER 3030	ADDRESSABLE	SDC PWR. RM.		
			2299 Pacific St., 92404						
18	HS	504	SIERRA		EDWARDS EST	ADDRESSABLE	ADMIN. OFFICE	2	40
		874	SIERRA INFANT		SIMPLEX 4001	ADDRESSABLE	INTERIOR W. WALL		
			570 E. 9th St., 92410						
19	OFFICE	908	WAREHOUSE		SIMPLEX 4010	ADDRESSABLE	PH. MPOE AREA	3	10

ADDENDUM 2

Scenarios (SCN#)

Scenario #1: Existing EST-3 Fire Alarm Control Panel with existing Partial Site EST-3 Security. Replace existing Silent Knight Panel with Terminal Can, run conduit (up to 150') and wire to existing EST-3 FA Panel and replace/install addressable modules as needed at each motion sensor or door contact.

Scenario #2: Same as #1 except add to existing EST-3 Fire Alarm Panel the Security component. Replace existing Silent Knight Panel with Terminal Can, run conduit (up to 150') and wire to existing EST-3 FA Panel and replace/install addressable modules as needed at each motion sensor or door contact.

Scenario #3: Change out existing Silent Knight Panel to a new EST-3 Security Panel. Replace/install addressable modules as needed at each motion sensor or door contact.