

San Bernardino City Unified School District

**PROPOSITION 39
ENERGY EFFICIENCY UPGRADES
EEP3**

**793 North E St, San Bernardino,
CA 92410**

ADDENDUM 06

February 27, 2019

Prepared By

**JOHN SERGIO FISHER & ASSOCIATES
5567 Reseda Blvd., Suite 209, Los Angeles, CA 91356
(818) 344-3045; FAX (818) 344-0338**

ADDENDUM 6

To: All bidders
From: John Fisher, AIA, Principal
**Project: SBCUSD Proposition 39 Energy Efficiency Upgrades EEP3
Phase 2 - Energy Upgrades**
Date: February 27, 2019

NOTICE TO BIDDERS

This Addendum forms a part of the Contract and modifies the original documents. It is intended that all work affected by the following modifications shall conform with related provisions and general conditions of the contract of the original drawings and specifications. Modify the following items wherever appearing in any drawing or sections of the specifications. Acknowledge receipt of Addendum No. 6 in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

• Please see attached drawing and files for:

- 1. Bid Package # 1 (Phase 2) – Pacific High School Pool Heaters - Revisions - Sheet M202**
- 2. Bid Package # 1 (Phase 2) – Pacific High School Pool Heaters - Structural calculation for pool heaters' supporting rack.**

End of Addendum

Job: _____
Engineer: _____
Contractor: _____
Prepared By: _____
Model: _____ Date: _____


SureRack® Kit

Stacking System for
Hi Delta® Boilers
Models 302B-2342B

Features

- ▶ Two-boiler Vertical Stack
- ▶ No Vent Offset Required
- ▶ Small Footprint
- ▶ Low Ceiling Height
- ▶ Heavy Duty Construction

See installation manual 240792



Hi Delta Model	Part No.	Weight (lbs.)	SureRack Kit (X-1) Dimensions (in.)			Cross Beams	Above-Grade Add-On (X-2)	Stacked Boiler Height (in.)
			A	B	W			
302B	006906	201	30	41-1/4	CTR.	3	P/N 007046	72-1/4
402B	006907	214		48-1/4				
502B	006908	228		55-1/4				
652B	006909	257		65-3/4				
752B	006910	265		72-3/4				
902B	006911	276	37-1/2	83-1/4		4	P/N 007053	87-1/2
992B	011563	340		64-1/8	16-13/16			
1262B	011564	361		75-1/2	20-9/16			
1532B	011565	371		87	26-3/8			
1802B	011566	408		98-1/8	30-1/8			
2002B	011567	430	108-1/2	108-1/2	33-15/16			
2072B	011567	430		108-1/2	33-15/16			
2342B	011568	458		121	37-11/16			

Raypak
A Honeywell Company

Catalog No.: 1000.92E Effective: 06-15-15 Replaces: 11-15-07



1. REMOVE EXISTING POOL HEATER CONTROL PANEL.
CAP AND PROTECT EXISTING CONDUIT AND WIRING FOR NEW CONTROL PANEL CONNECTION.
CONTRACTOR TO PROVIDE ADEQUATE EXTENSION FOR THE NEW CONNECTION.

PHOTO #5 - (E) BOILER CONTROL PANEL

SCALE

NONE

2




1. TEMPORARY REMOVE ALL THE UTILITY PIPING UP TO POINT OF REMOVALS AS INDICATED.

PHOTO #4 - (E) COLD WATER, GAS, ELEC. CONNECTIONS

SCALE

NONE

1



BOILER SURERACK KIT AND ANCHORAGE

SCALE

NONE

3

GENERAL NOTES

John Sergio Fisher
Professional Engineer
No. 26903
Renewal: 9/30/20
MECHANICAL
STATE OF CALIFORNIA

MAROKO & SHWE, INC.
Mechanical Engineers
1106-B W. MAGNOLIA BLVD.,
BURBANK, CA 91506
(818) 840-0280 FAX(818) 840-0294

SUBMITTALS:

NO.	DESCRIPTION	DATE

The enclosed drawings, designs, ideas and arrangements, as contracted with their clients and consultants, are and shall remain the property of John Sergio Fisher & Associates Inc. No part thereof shall be copied, disclosed to others, or used in connection with any other work or project without the written consent of the above. Visual contact with these prints shall constitute conclusive evidence of these restrictions.

John Sergio Fisher & Associates Inc.
5567 Reseda Blvd #209
Tarzana California 91356
(818) 344-3045
fax (818) 344-0338
E-mail: mail@jsfarchs.com
Architecture & Planning
John Fisher AIA

jsfa



IDENTIFICATION STAMP
DIVISION OF THE STATE ARCHITECT
OFFICE OF REGULATION SERVICES

FILE #
APPL: 04-117886

AC: _____ F/L: _____ SS: _____
DATE: _____

KEY PLAN


Client:
SAN BERNARDINO CITY UNIFIED SCHOOL DISTRICT
PROP 39 ENERGY PROJECTS
Job Name:
**PACIFIC HIGH SCHOOL
POOL HEATER REPLACEMENT**
DISTRICT OFFICE:
777 NORTH F STREET, SAN BERNARDINO, CA 92407
Drawing Title

DETAILS

Project No: 1715
Phase: JANUARY 21, 2019
Drawing No:
Date:
Scale: AS SHOWN

M 202


MARK	MAKE	MODEL	WEIGHT
UPPER BOILER UNIT	RAYPACK	1532B	1225 LBS.
LOWER BOILER UNIT	RAYPACK	1532B	1225 LBS.




ELEVATION VIEW
SCALE: 1/2" = 1'-0"

NOTE(S):

1. USE 1/2" ϕ ASTM A 193 Gr B7 CARBON STEEL THREADED ROD W/ A-194 NUT, MIN. 4" EMBEDMENT, MIN. 6" EDGE DISTANCE, & MIN. 8" CONC. THICKNESS (4" THICK HKP + 4" THICK SLAB) IN MIN. 3000 PSI HARDROCK CONCRETE. INSTALL W/ HAMMER DRILL & CARBIDE BIT & SET W/ HIT-RE 500-SD ADHESIVE AS PER THE ICC ESR-2322. INSTALL WITH SPECIAL INSPECTION PER THE ICC-2322.
2. M.W. SAUSSE' & CO. INC. IS NOT RESPONSIBLE FOR STRUCTURAL INTEGRITY OF THE EQUIPMENT/UNIT WHEN ANCHORED AS SHOWN.
3. ALL HARDWARE & MATERIALS TO BE SUPPLIED BY OTHERS.
4. THIS DESIGN IS ONLY APPLICABLE FOR UNIT INSTALLED ON GRADE.
5. RAYPAK SURERACK X-2 ADD-ON NOT NEEDED FOR INSTALLATION.



PLAN VIEW
SCALE: 1/2" = 1'-0"



**ANCHOR PLATE
DETAIL**
SCALE: 3" = 1'-0"



M. W. SAUSSE' & CO., INC.

28744 WITHERSPOON PKWY, VALENCIA, CA 91355
PHONE: (661) 257-3311 FAX: (661) 257-7673

Vibrex STEEL FRAME STAND
vibration & seismic control systems

JOB NAME : PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS

CUST : MAROKO & SHWE, INC.

CUST. P.O. :

MECH. ENGR. :

MARK : RAYPAK SURERACK SUPPORT FRAME

REVISIONS :

A :

B :

C :

DRN : FS

ENG : FS

DATE : 2/12/19

DRAWING NO. :

63592-1

CALCULATIONS FOR RIGID ANCHORAGE; 2016 CBC & ASCE 7-10

CALL OUTS WORTH CASE LOADING FOR (4) ANCHOR POINTS. (UNITS: LBS & INCHES)
USING COMBINED LOAD EQUATIONS 16-5: $U = 1.2D + 1.0E$ & 16-7: $U = 0.9D + 1.0E$



$$\begin{aligned} I_x &= 4 \cdot B \cdot B^3 &= 1406.25 \\ I_y &= 4 \cdot L \cdot L^3 &= 7569.00 \end{aligned}$$

$$\begin{aligned} \gamma & \text{ (DIR. OF VROT-CRIT. ANCHOR): } \tan^{-1}(B/L) &= 23.32 \\ \alpha & \text{ (DIR. OF VDIR-CRIT. ANCHOR): } \tan^{-1}(E_y/E_x) &= 23.32 \\ \beta &: \gamma - \alpha = &= 180.00 \\ \theta & \text{ (DIR. OF } F_{ph} \text{ FOR MAX UPLIFT): } \tan^{-1}((L \cdot I_y)/(B \cdot I_x)) &= 23.32 \end{aligned}$$

$$\begin{aligned} \text{VERTICAL REACTIONS (WITH 0.9D OR 1.2D):} & F_{ph} \text{ ACTS IN MOST CRITICAL DIRECTION.} \\ R_{ov} & \text{ (DUE TO OVERTURNING MOMENT)} &= 530.18 \\ R_{e_{max}} & \text{ (DUE TO ECCENTRICITY):} &= 98.35 \\ R_{e_{min}} & \text{ (DUE TO ECCENTRICITY):} &= 61.25 \\ R_{v_{max}} & \text{ (DUE TO VERTICAL LOADS):} &= 571.54 \\ R_{v_{min}} & \text{ (DUE TO VERTICAL LOADS):} &= 266.36 \\ P_{max} & \text{ (MAX DOWNWARD REACTION): } R_m + R_{e_{max}} + R_{v_{max}} &= 1200.06 \\ P_{min} & \text{ (MAX UPLIFT/ANCH. POINT - IF POS.): } R_m + R_{e_{min}} + R_{v_{min}} &= 325.07 \\ P_{min} & \text{ (MAX UPLIFT/ANCH. POINT - IF POS.): } \Omega_0 R_m + R_{e_{min}} + R_{v_{min}} &= 1120.34 \end{aligned}$$

$$\begin{aligned} \text{HORIZONTAL REACTIONS:} \\ V_{tot} & \text{ (SHEAR DUE TO ECCENTRICITY):} &= 7.42 \\ V_{dir} & \text{ (DIRECT SHEAR):} &= 139.11 \\ V_{max} & \text{ (TOTAL SHEAR/ANCH. POINT):} &= 146.53 \\ \Omega_0 V_{max} & \text{ (TOTAL SHEAR/ANCH. POINT):} &= 355.19 \end{aligned}$$

ANCHOR BOLTS:

SEE SHEET 63517-C1.4 FOR ANCHOR BOLT DESIGN.

$$\begin{aligned} \text{ANCHOR BOLT DIAMETER:} &= 1/2 \\ \text{TYPE OF ANCHOR BOLT: CARBON STEEL HILTI HIT-RE 500 V3 ADHESIVE ANCHOR BOLT IN MIN.} \\ & \text{3000psi HARDROCK CONCRETE. SEE THE FOLLOWING SHEETS FOR ANCHOR BOLT DESIGN AND} \\ & \text{COMBINED LOADING CHECK.} \end{aligned}$$

FOR DESIGN OF THE VERTICAL MEMBERS/LEGS OF THE STAND:

$$\begin{aligned} P_{max}: R_m + R_{e_{max}} + R_{v_{max}} &= 1200.06 & \text{MAX DOWNWARD REACTION ON LEG} \\ V_{max}: &= 146.53 & \text{MAX SHEAR LOAD ON LEG} \end{aligned}$$

$$\begin{aligned} \text{HORIZONTAL SEISMIC FORCE:} \\ 13.3-2: F_{ph} &= 1.6 \cdot S_{ds} \cdot I_p \cdot W_p \text{ (MAX)} &= 2967.62 \\ 13.3-1: F_{ph} &= (0.4 \cdot a_p \cdot S_{ds} / (R_p / I_p)) \cdot (1 + 2z/h_r) \cdot W_p &= 296.76 \\ 13.3-3: F_{ph} &= 0.3 \cdot S_{ds} \cdot I_p \cdot W_p \text{ (MIN)} &= 556.43 \end{aligned}$$

$$\begin{aligned} \text{CONTROLLING HOR. SEISMIC FORCE: } F_{ph} &= 556.43 \\ \text{OVERTURNING MOMENT: } M &= F_{ph} \cdot H_{cg} &= 36515.68 \\ \text{VERTICAL SEISMIC FORCE: } F_{pv} &= 0.2 \cdot S_{ds} \cdot W_p &= 370.95 \\ \text{SPECTRAL RESP. ACCEL'N: } S_{ds} &= 2/3 \cdot F_a \cdot S_a &= 1.16 \\ \text{- SITE COEFFICIENT (TABLE 1615.1.2): } F_a &= 0.80 &= 0.80 \\ \text{- MAPPED SPECTRAL ACCEL'N (FIG. 1615(3)): } S_a &= 2.18 &= 2.18 \\ \text{IMPORTANCE FACTOR: } I_p &= 1.00 &= 1.00 \\ \text{COMPONENT AMPLIFICATION FACTOR: } a_p &= 1.00 &= 1.00 \\ \text{COMP. RESPONSE MODIFICATION FACTOR: } R_p &= 2.50 &= 2.50 \\ \text{EQUIPMENT ELEVATION / ROOF ELEVATION: } z/h_r &= 0.00 &= 0.00 \end{aligned}$$

$$\begin{aligned} \text{(WITH RESPECT TO GRADE)} \\ \text{EQUIPMENT + STAND WEIGHT: } W_p \text{ (lbs)} &= 1596.00 \\ L: &= 43.50 \\ B: &= 18.75 \\ E_x: &= 4.35 \\ E_y: &= 1.88 \\ \text{HEIGHT TO CG. UNIT: } H_{cg} &= 21.88 \\ \text{HEIGHT OF STAND: } H_s &= 43.75 \end{aligned}$$



JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M. W. SAUSSE' & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY : F5
MECH. ENG.:		DATE : 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO. : 63592-C1.0


CALCULATIONS FOR RIGID ANCHORAGE TO CONCRETE; 2015 IBC/2016 CBC & ASCE 7-10, LRFD

CALCULATES WORST CASE LOADING FOR (4) ANCHOR POINTS. (UNITS: LBS & INCHES)

USING COMBINED LOAD EQUATIONS 16-4, 16-5, 16-6, & 16-7

SEISMIC/WIND FORCES - CH. 13, 26, & 29 OF ASCE 7

13.3-2: $F_p = \Omega_0 1.6 S_{ds} I_p W_p$ (MAX)	=	5694.45 lbs
13.3-1: $F_p = \Omega_0 (0.4 a_p S_{ds} / (R_p I_p)) (1 + 2z/h_r) W_p$	=	569.45 lbs
13.3-3: $F_p = \Omega_0 0.3 S_{ds} I_p W_p$ (MIN)	=	1067.71 lbs
Ω_0 PER ASCE 7-10, NOTE C, TABLE 13.6-1	=	2.50
CONTROLLING HOR. SEISMIC FORCE: F_p	=	1067.71 lbs
SEISMIC OVERTURNING MOMENT: $M = F_{ph} H_{c.g.}$	=	23356.16 lb-in
VERTICAL SEISMIC FORCE: $F_{pv} = 0.2 S_{ds} W_p$	=	284.72 lbs
SPECTRAL RESP. ACCEL'N: S_{ds}	=	1.16
IMPORTANCE FACTOR: I_p	=	1.00
COMPONENT AMPLIFICATION FACTOR: a_p	=	1.00
COMP. RESPONSE MODIFICATION FACTOR: R_p	=	2.50
EQUIPMENT ELEVATION / ROOF ELEVATION: z/h_r (WITH RESPECT TO GRADE)	=	0.00



EQUIPMENT WEIGHT & GEOMETRY

EQUIPMENT WEIGHT: W_p	=	1225.00 lbs
L:	=	43.50 in
B:	=	18.75 in
E_x :	=	4.35 in
E_y :	=	1.88 in
HEIGHT TO CG: $H_{c.g.}$	=	21.88 in
NO. OF ANCHORS PER POINT (N)	=	1.00

ANCHOR GROUP FORCES

$l_x = 4 \cdot B \cdot B$	=	1406.25 in ⁴
$l_y = 4 \cdot L \cdot L$	=	7569.00 in ⁴
γ (DIR. OF Vrot-CRIT. ANCHOR): $\tan^{-1}(B/L)$	=	23.32
α (DIR. OF Vdir-CRIT. ANCHOR): $\tan^{-1}(E_y/E_x)$	=	23.32
β : $\gamma - \alpha =$	=	180.00
θ (DIR. OF F_{ph} FOR MAX UPLIFT): $\tan^{-1}((L \cdot l_x)/(B \cdot l_y))$	=	23.32

FROM SEISMIC LOADS (LOAD APPLIED TO CRITICAL ANGLE)

VERTICAL REACTIONS (WITH 1.2D OR 0.9D):

R_m (DUE TO OVERTURNING MOMENT)	=	339.11 lbs
$R_{e \text{ MAX}}$ (DUE TO ECCENTRICITY):	=	87.74 lbs
$R_{e \text{ MIN}}$ (DUE TO ECCENTRICITY):	=	40.89 lbs
$R_{v \text{ MAX}}$ (DUE TO VERTICAL LOADS):	=	438.68 lbs
$R_{v \text{ MIN}}$ (DUE TO VERTICAL LOADS):	=	204.44 lbs
P_{MAX} (MAX DOWNWARD REACTION): $R_m + R_{e \text{ MAX}} + R_{v \text{ MAX}}$	=	865.53 lbs
P_{MIN} (MAX UPLIFT/ANCH. POINT - IF POS.): $R_m + R_{e \text{ MIN}} - R_{v \text{ MIN}}$	=	175.56 lbs
P_{MIN} (NO OVERSTRENGTH): $R_m / \Omega_0 + R_{e \text{ MIN}} - R_{v \text{ MIN}}$	=	0.00 lbs

HORIZONTAL REACTIONS:

V_{rot} (SHEAR DUE TO ECCENTRICITY):	=	26.69 lbs
V_{dir} (DIRECT SHEAR):	=	266.93 lbs
V_{MAX} (TOTAL SHEAR/ANCH. POINT):	=	293.62 lbs
V_{MAX} (NO OVERSTRENGTH):	=	117.45 lbs



ANCHOR BOLT DIAMETER:	=	1/2
TYPE OF ANCHOR BOLT: CARBON STEEL HILTI HIT-RE 500 V3 ADHESIVE ANCHOR BOLT IN MIN. 3000psi HARDROCK CONCRETE. SEE THE FOLLOWING SHEETS FOR ANCHOR BOLT DESIGN AND COMBINED LOADING CHECK.		

JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M.W. SAUSSE' & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY : FS
MECH. ENG.:		DATE : 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO. : 63592-C1.1

COLUMN CHECK - 2016 CBC & ASCE 7-10 - LRFD DESIGN

COLUMN HEIGHT AND FORCES

FROM SHEET- 63592-C1.0

$$\begin{aligned} P_H &= V_{MAX} = 146.53 \text{ lbs} \\ P_V &= P_{MAX} = 1200.064 \text{ lbs} \\ H_{column} &= 43.75 \text{ in} \end{aligned}$$

COLUMN PROPERTIES

ANGLE 2-1/2 X 2-1/2 X 3/8

$$\begin{aligned} K &= 2.0 \text{ (PINNED BOTTOM, FREE TRANSLATION FIXED ROTATION TOP)} \\ r &= 0.749 \text{ in} \\ A_g &= 1.73 \text{ in}^2 \\ Z_{min} &= 1.010 \text{ in}^3 \\ I_{min} &= 0.972 \text{ in}^4 \\ f_{yield} &= 36000 \text{ psi} \end{aligned}$$

COLUMN CHECK

DEMAND -

$$\begin{aligned} P_u &= P_v = 1200 \text{ lbs} \\ M_u &= P_H \cdot H_{column} = 6411 \text{ lb-in} \end{aligned}$$

CAPACITY -

$$\begin{aligned} K(H_{column})/r &= 117 \\ 0.9F_{cr} &= 38300 \text{ psi} \\ P_n &= 0.9A_g \cdot F_{cr} = 66259 \text{ lbs} \\ M_n &= f_{yield} \cdot Z_{min} = 32724 \text{ lbs} \end{aligned}$$


COMBINED LOAD CHECK -

$$1.02 \frac{P_u}{P_n} + \frac{M_u}{M_n} = 0.21 \text{ OKI}$$

CHECK DEFLECTIONS

COLUMN -

$$\begin{aligned} \Delta_{MAX} &\leq H_{column}/180 = 0.243 \text{ in} \\ \Delta_{COLUMN} &= \frac{P_H H_{column}^3}{3EI_{min}} = 0.145 \text{ DEFLECTION OK} \end{aligned}$$



USE 2-1/2 X 2-1/2 X 3/8" ANGLE FOR STAND LEGS.

JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M. W. SAUSSÉ & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY: FS
MECH. ENG.:		DATE: 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO.: 63592-C1.2

ANCHOR BOLT FORCE CALCULATION FOR CUSTOM RMLS BASEPLATE LAYOUT

ISOLATOR FORCES AND DIMENSIONS

MOUNTING HOLE	X	Y
1.00	0.00	0.00
2.00	5.00	0.00
3.00	5.00	5.00
4.00	0.00	5.00
#N/A	0.00	0.00
#N/A	0.00	0.00
#N/A	0.00	0.00
#N/A	0.00	0.00
#N/A	0.00	0.00
#N/A	0.00	0.00
#N/A	0.00	0.00





PLATE FORCES SHEET 63592-C1.0 THRU C1.2 (W/ Ω_0)

V_x (UPPER + LOWER UNIT)	=	648.81
P_y (UPPER + LOWER UNIT)	=	1295.89
V_z (UPPER + LOWER UNIT)	=	0.00
M_x	=	0.00
M_y	=	0.00
M_z	=	16026.33
N: # OF MOUNTING HOLES IN BASEPLAT	=	4

	X	Y
BOLT PATTERN DIM	5.00	5.00
LOADING CENTER F	0.85	0.36
CTR. OF RIGIDITY:	2.50	2.50
MOM. OF INERTIA: I_y	25.00	25.00




VERTICAL REACTIONS:

$T_1 = M_x * [((e_x / l_y)^2 * \cos(\theta)) + ((e_y / l_y)^2 * \sin(\theta))]$	=	0.00 DUE TO MOMENT, M_x
$T_2 = M_z * [((e_x / l_y)^2 * \cos(\theta)) + ((e_y / l_y)^2 * \sin(\theta))]$	=	230.78 DUE TO MOMENT, M_z
$T_3 = P_y / n$	=	323.97 DUE TO UPLIFT, P_y
$T_4 = P_y * [(e_x - c_x) / (b_x / (2 * l_y)) + (e_y - c_y) / (b_y / (2 * l_y))]$	=	491.14 DUE TO ECCENTRICITY, P_y
$T_{ab} = T_1 + T_2 + T_3 + T_4$	=	1045.90 TOTAL TENSION / BOLT

HORIZONTAL REACTIONS:

$V_1 = V_x / n$	=	162.20 DIRECT SHEAR, V_x
$V_2 = V_z / n$	=	0.00 DIRECT SHEAR, V_z
$V_3 = V_x * [(e_x - c_x)^2 + (e_y - c_y)^2]^{1/2} / (b / 2^{1/2})$	=	123.97 SHEAR DUE TO ECCENTRICITY, V_x
$V_3 = V_z * [(e_x - c_x)^2 + (e_y - c_y)^2]^{1/2} / (b / 2^{1/2})$	=	0.00 SHEAR DUE TO ECCENTRICITY, V_z
$V_4 = M_y / (b / 2^{1/2})$	=	0.00 SHEAR DUE TO ROTATION, M_y
$V_{ab} = (V_1^2 + V_2^2 + (V_3 + V_4)^2)^{0.5}$	=	204.15 TOTAL SHEAR / BOLT



BASEPLATE PROPERTIES

b =	2.5
W =	8
$t_{plate} =$	0.25
$f_{yield} =$	36000

PLATE CHECK

$M_{plate} = (2T_{max} / \Omega_0) * e =$	4.64	in
$M_{plate} = (2T_{max} / \Omega_0) * e =$	3882.37	lb-in
$Z_{plate} = W * t_{plate}^2 / 4 =$	0.125	in ³
$M_n = 0.9f_{yield}Z_{plate} =$	4050	lb-in > M_{plate} OK!!

WELD FRAME BASE TO MIN. 8X8X1/4" A36 STEEL BASEPLATE WITH 3/16" FILLET WELDS MIN. (WELDS OK PER INSPECTION). SEE THE FOLLOWING SHEETS FOR ANCHOR BOLT DESIGN.

JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M. W. SAUSSE' & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY : FS
MECH. ENG.:		DATE : 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO. : 63592-C1.3

HILTI HIT-RE 500 V3 ADHESIVE ANCHORS IN CONCRETE
(U.S. CUSTOMARY UNITS, ESR-3814 (REISSUED JANUARY '17) AND ACI-318 CHAPTER 17)

ANCHOR SPECIFICATIONS/PARAMETERS

INPUT	ANCHOR TYPE: THREADED ROD
	STEEL TYPE: CARBON
	GRADE: A 193 Gr B7
	DIAMETER (d_o) = 0.5 in
	$n = 4$ (NUMBER OF BOLTS PER ANCHOR POINT)
	TEMPERATURE RANGE: A (A: MAX LONG TERM TEMP = 110°F, SHORT TERM = 130°F, B: MAX LONG TERM TEMP = 110°F, SHORT TERM = 176°F, NOTE 2, TABLE 9 OF ESR)
	SEISMIC CONDITIONS?: YES

STEEL STRENGTH (TENSION AND SHEAR)

$\alpha_{V,scia} =$	1 (TABLE 6 OF ESR)
$\Phi_{sN} =$	0.75 (TENSION STRENGTH REDUCTION FACTOR FOR DUCTILE STEEL; ACI-318 17.3.3)
$\Phi_{sV} =$	0.65 (SHEAR STRENGTH REDUCTION FACTOR FOR DUCTILE STEEL; ACI-318 17.3.3)
$A_{sa} =$	0.1418 in ² (TABLE 6 FROM ESR)
$N_{sa} =$	17735 lbs (TABLE 6 FROM ESR)
$V_{sa} =$	10640 lbs (TABLE 6 FROM ESR)
$\Phi_{sN} * N_{sa} =$	13301.3 lbs (ACI 318, 17.4.1.2) ← DESIGN STEEL TENSION STRENGTH
$\Phi_{sV} * V_{sa} * \alpha_{V,scia} =$	6916 lbs (ACI 318, 17.5.1.2) ← DESIGN STEEL SHEAR STRENGTH

CONCRETE


BREAKOUT TENSION

$h_{min} =$	5.25 in (MIN. CONCRETE THICKNESS, TABLE 7 OF ESR)
$S_{min} =$	2.5 in (MIN. ANCHORAGE SPACING, TABLE 7 OF ESR)
$C_{a,min} =$	2.5 in (MIN. ALLOWABLE EDGE DISTANCE, TABLE 7 OF ESR)
$h_{ef,min} =$	2.375 in (MIN. ALLOWABLE EFFECTIVE EMBEDMENT, TABLE 7 OF ESR)
$h_{ef,max} =$	10 in (MAX. ALLOWABLE EFFECTIVE EMBEDMENT, TABLE 7 OF ESR)
$h_{ef} =$	4 in (CHOSEN EFFECTIVE EMBED. USE AT LEAST $h_{ef,min}$ FROM ABOVE)
$h_a =$	8 in (MEMBER THICKNESS. IF UNKNOWN USE h_{min} , TABLE 7 IN ESR)

FOR CRITICAL EDGE DISTANCE FROM SECTION 4.1.10....

$$C_{ac} = h_{ef} \left(\frac{f_c}{1160} \right)^{0.4} \text{ MAX} \left[3, 1 - 0.7 \frac{h_a}{h_{ef}}, 1.4 \right] = 7.87 \text{ in} \quad \text{GIVEN } f_{c,unior} = 1673.717 \text{ psi}$$

WHERE $f_{c,unior} \leq k_{c,unior} (h_{ef} f_c)^{1/2} / (\pi d)$



$C_{a1} =$	6 in (USE AT LEAST $C_{a,min}$)
$C_{a2} =$	6 in (USE AT LEAST $C_{a,min}$ & $\geq C_{a1}$)
$C_{a3} =$	9 in (USE AT LEAST $C_{a,min}$ & $\geq C_{a2}$)
$C_{a4} =$	9 in (USE AT LEAST $C_{a,min}$ & $\geq C_{a2}$)
$S_1 =$	5 in (USE AT LEAST MIN. SPACING, ESR TABLE 7; USE 0 IF $n=1$)
$S_2 =$	5 in (USE AT LEAST MIN. SPACING, ESR TABLE 7; USE 0 IF $n=1$)
$f_c =$	3000 psi (CONCRETE STRENGTH)
$\lambda_a =$	1.00 (ACI-318, 17.2.6)
HARDROCK CONCRETE	
$k_c =$	17 (UNCRACKED = 24, CRACKED = 17; ESR TABLE 7)
$\Psi_{ec,N} =$	1 (ACI 17.4.2.4; 1.0 WHEN NO LOAD ECCENTRICITY)
$\Psi_{c,N} =$	1 (ACI 17.4.2.6; 1.0 WITH CRACKING AT SERVICE LEVELS)
$\Phi_{cN} =$	0.65 (TENSION CONCRETE BREAKOUT STRENGTH REDUCTION TABLE 7)
$h_{ef} \text{ CHECK} = h_{ef}^* =$	4 in (IF 3 OR MORE EDGES ARE LESS THAN $1.5 * h_{ef}$, 17.4.2.3 OF THE ACI-318)

$$SIDE_{\perp} = \min(C_{a2}, 1.5h_{ef}) + S_2 + \min(C_{a1}, 1.5h_{ef}) = 17 \text{ in}$$

$$SIDE_{\parallel} = \min(C_{a1}, 1.5h_{ef}) + S_1 + \min(C_{a3}, 1.5h_{ef}) = 17 \text{ in}$$

$$A_{Nc} = SIDE_{\perp} * SIDE_{\parallel} = 289 \text{ in}^2 \text{ (PROJECTED FAILURE SURFACE AREA, ACI-318 17.4.2.1)}$$

$$A_{NcO} = n * 9 * (h_{ef})^2 = 576 \text{ in}^2 \text{ (PROJECTED FAILURE SURFACE AREA OF SINGLE ANCHOR WITHOUT INFLUENCE ACI-318 17.4.2.1)}$$

$$\Psi_{ed,N} = 0.7 + 0.3 * C_{a1} / (1.5 * h_{ef}) = 1.00 \text{ (IF } C_{a1} \geq 1.5h_{ef} \text{ THEN } = 1.0)$$



$$\Psi_{op,N} = \frac{\max(C_{a1}, 1.5h_{ef})}{C_{ac}} = 0.762 \leq 1.0 \text{ (IF LARGER THAN 1 USE } \Psi_{op,N} = 1.0)$$

$$N_b = \lambda_a k_c * \sqrt{f_c} * (h_{ef})^{1.5} = 7449.03 \text{ lbs}$$

$$N_{cb} = \frac{A_{Nc}}{A_{NcO}} \Psi_{ec,N} \Psi_{ed,N} \Psi_{c,N} \Psi_{op,N} N_b = \text{N/A (MORE THAN ONE ANCHOR)}$$

$$N_{cb} = \frac{A_{Nc}}{A_{NcO}} \Psi_{ec,N} \Psi_{ed,N} \Psi_{c,N} \Psi_{op,N} N_b = 2847.92$$

$$\Phi_{cN} N_{cb} = 1851.15 \text{ lbs} \leftarrow \text{DESIGN CONCRETE BREAKOUT STRENGTH IN TENSION}$$



JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M. W. SAUSSE' & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY: FS
MECH. ENG.:		DATE: 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO.: 63592-C1.4

CHECK SIDE-FACE BLOWOUT

$$A_{brg} = 0.1418 \text{ in}^2 \text{ (BEARING AREA OF CONCRETE AT ANCHOR BOTTOM. USE } A_{brg} \text{ TO BE CONSERVATIVE)}$$

FOR SINGLE ANCHORS -

$$\text{CHECK } C_{a2} \rightarrow C_{a2} < 3C_{a1} \rightarrow 6 < 18$$

$$\text{REDUCTION FACTOR FROM } C_{a2} = \frac{1 + C_{a2}/C_{a1}}{4} = 0.5 \rightarrow \text{WHERE } 1.0 \leq C_{a2}/C_{a1} \leq 3.0 \rightarrow \text{TRUE!}$$

$$N_{sb} = 160C_{a1}\sqrt{A_{brg}}\sqrt{f_c} = 19800.2 \text{ lbs} \rightarrow \text{REDUCED VALUE} = 9900.1 \text{ lbs (ACI 318, 17.4.4.1)}$$

FOR MULTIPLE ANCHORS (GROUPS) -


$$\text{CHECK BOLT SPACING} \rightarrow S < 6C_{a1} \rightarrow 5 < 36$$

$$N_{sbg} = \left(1 + \frac{S}{6C_{a1}}\right) N_{sb} = 22550.2 \text{ lbs (ACI-318 17.4.4.2)}$$

$$\Phi_{cb} N_{sbg} = 14657.7 \text{ lbs} \leftarrow \text{CONCRETE SIDE-FACE BLOWOUT STRENGTH}$$

SHEAR STRENGTH

- $d_o = 0.5 \text{ in (OUTSIDE DIAMETER OF ANCHOR BOLT OR ROD)}$
- $C_{a1} = 6 \text{ in (FROM PREVIOUS PAGE OF CALCULATIONS)}$
- $C_{a2} = 6 \text{ in (FROM PREVIOUS PAGE OF CALCULATIONS)}$
- $C_{a4} = 9 \text{ in (FROM PREVIOUS PAGE OF CALCULATIONS)}$
- $S_2 = 5 \text{ in (FROM PREVIOUS PAGE OF CALCULATIONS)}$
- $\ell_e = 4 \text{ in (TYPICALLY } = h_{ef}, \text{ NO MORE THAN } 8d_o \text{ ACI-318 SECTION 17.5.2.2)}$
- $\Psi_{ec,V} = 1 \text{ (ACI 17.5.2.5; 1.0 WHEN NO LOAD ECCENTRICITY)}$
- $h_a = 8 \text{ in (THICKNESS OF CONCRETE MEMBER)}$
- $\Phi_{cb} = 0.70 \text{ (SHEAR CONCRETE BREAKOUT STRENGTH REDUCTION; ACI-318 \& ESR TABLES B OR 24)}$
- $\Psi_{c,V} = 1.2 \text{ (1.0 FOR CONC. W/O REINFORCEMENT, 1.2 FOR CONC. W/ REINFORCEMENT, 1.4 SEE 17.5.2.7 OF ACI)}$
- $n_v = 2 \text{ (NO. OF ANCHORS IN ROW CLOSEST TO EDGE OF CONCRETE)}$
- $C_{a1}' = 6.00 \text{ in (} C_{a1} \text{ ADJUSTED WHEN } C_{a2} \& C_{a4} \text{ ARE LESS THAN } 1.5C_{a1}, \text{ 17.5.2.4)}$



$$H = \min(h_a, 1.5C_{a1}') = 8 \text{ in}$$

$$B = \min(C_{a2}, 1.5C_{a1}') + S_2 + \min(C_{a4}, 1.5C_{a1}') = 20.000 \text{ in}$$

$$A_{Ve} = B \cdot H = 160.0 \text{ in}^2 \text{ (REFER TO ACI-318 17.5.2.1 AND 17.5.2.2)}$$

$$A_{VcO} = n_v \cdot 4.5(C_{a1}')^2 = 324.0 \text{ in}^2 \text{ (REFER TO ACI-318 D.6.2.1 AND 17.5.2.2)}$$

$$\Psi_{h,V} = (1.5C_{a1}'/h_a)^{1/6} = 1.06 \text{ (} \geq 1.0, \text{ FROM ACI-318 SECTION 17.5.2.8)}$$

$$\Psi_{ed,V} = 0.7 + 0.3 \cdot C_{a2}' / (1.5 \cdot C_{a1}') = 0.90 \text{ (IF } C_{a2} > 1.5h_a \text{ THEN } = 1.0, \text{ ACI 318 17.5.2.6)}$$

$$V_b = 7 \left(\frac{\ell_e}{d_o} \right)^{0.2} \sqrt{d_o} \sqrt{f_c} (C_{a1}')^{1.5} = 6039.3 \text{ OR } V_b = 9\lambda_a (f_c')^{1/2} \cdot C_{a1}'^{1.5} = 7244.86$$

$$V_{cb} = \frac{A_{Ve}}{A_{VcO}} \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_b = \text{N/A (MORE THAN ONE ANCHOR)}$$

$$V_{cb} = \frac{A_{Ve}}{A_{VcO}} \Psi_{ec,V} \Psi_{ed,V} \Psi_{c,V} \Psi_{h,V} V_b = 3416.36$$

$$\Phi_{cb} V_{cb} = 2391.45 \text{ lbs} \leftarrow \text{DESIGN SHEAR CONCRETE STRENGTH}$$



EPOXY BOND STRENGTH (PULLOUT)

PULLOUT STRENGTH

$$\tau_{cr} = 1305.2 \text{ psi (CHARACTERISTIC BOND STRENGTH; ESR TABLE B \& 11 \& NOTE \#1)}$$

$$\tau_{uncr} = 2342.3 \text{ psi (CHARACTERISTIC BOND STRENGTH; ESR TABLE B \& 11 \& NOTE \#1)}$$

$$d_a = 0.5 \text{ in (STEEL ANCHOR DIAMETER)}$$

$$\Psi_{ec,Na} = 1 \text{ (LOAD ECCENTRICITY FACTOR, SEE EQ. 17.4.5.3 ACI 318)}$$

$$\Phi_d = 0.65 \text{ (EPOXY BOND STRENGTH REDUCTION; ESR, TABLE B \& 11)}$$

$$\alpha_{N,ecis} = 0.93 \text{ (TABLES B \& 11 OF ESR)}$$

$$\lambda_a = 1.00 \text{ (ACI-318, 17.2.6)}$$

JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M. W. SAUSSE & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY: FS
MECH. ENG.:		DATE: 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO.: 63592-C1.5

$$C_{Na} = 10d_a(\tau_{uncr}/1100)^{1/2} = 7.30 \text{ in (CRITICAL EDGE DISTANCE; ACI 318, EQ. 17.4.5.1d)}$$

$$SIDE_{||} = \min(C_{Na1}C_{a1}) + S_1 + \min(C_{Na2}C_{a2}) = 18.30 \text{ in}$$

$$SIDE_{\perp} = \min(C_{Na1}C_{a2}) + S_2 + \min(C_{Na2}C_{a1}) = 18.30 \text{ in}$$

$$A_{Na} = SIDE_{||} \times SIDE_{\perp} = 334.75 \text{ in}^2 \text{ (PROJECTED FAILURE SURFACE AREA, ESR SECTION 4.1.4, ACI-318 17.4.5.1)}$$

$$A_{NaO} = n(2C_{Na})^2 = 851.75 \text{ in}^2 \text{ (PROJECTED FAILURE SURFACE AREA OF SINGLE ANCHOR WITHOUT INFLUENCE ESR SEC. 4.1.4, ACI-318 17.4.5.1)}$$

$$\Psi_{ed,Na} = 0.7 + 0.3 \cdot C_{a1}/C_{cr,Na} = 0.95 \text{ (IF } C_{a1} \geq C_{Na} \text{ THEN } = 1.0; \text{ EQN 17.4.5.4a \& 17.4.5.4b)}$$

$$\Psi_{cp,Na} = C_{a1}/C_{ac} = 1.0 \text{ psi (ESR SECTION 4.1.4, TABLES 8 OR 24)}$$

$$N_{ps} = \lambda_a \tau_{cr} \pi d_a h_{ef} = 8200.89 \text{ lbs (ESR SECTION 4.1.4, EQ. 17.4.5.2)}$$

$$N_a = \frac{A_{Na}}{A_{NaO}} \Psi_{ed,Na} \Psi_{cp,Na} N_{ps} = \text{N/A (MORE THAN ONE ANCHOR)}$$

$$N_a = \frac{A_{Na}}{A_{NaO}} \Psi_{ed,Na} \Psi_{cp,Na} N_{ps} = 3051.29$$

$$\alpha_{N,des} \Phi_d N_a = 1844.5 \text{ lbs} \leftarrow \text{DESIGN EPOXY BOND (PULLOUT) STRENGTH}$$

PRYOUT FROM SHEAR STRENGTH (ESR SECTION 4.1.7)

$$V_{cp} = \min(k_{cp} \Phi_{sh} N_a; k_{cp} \Phi_{sh} N_{cb}) = 3689.01 \text{ lbs} \leftarrow \text{DESIGN PRYOUT (DUE TO SHEAR) STRENGTH}$$

CONTROLLING STRENGTH FOR ANCHORAGE

TENSILE STRENGTH -

$$STEEL = 13301.3$$

$$CONCRETE = 1851.1$$

$$EPOXY BOND = 1844.5 \leq \text{CONTROLLING STRENGTH}$$

$$SIDE-FACE BLOWOUT = 14657.7$$

SHEAR STRENGTH -

$$STEEL = 6916$$

$$CONCRETE = 2391.45 \leq \text{CONTROLLING STRENGTH}$$

$$PRYOUT STRENGTH = 3689.01$$

FOR ASD ADJUSTMENT FACTORS AND ALLOWABLE LOADS

INPUT...

$$\alpha = 1.00 \text{ (ASD CONVERSION FACTOR, IF APPLICABLE.)}$$

$$\text{SEISMIC TENSION FACTOR (F}_{SCN}) = 0.75 \text{ (PER SECTION 17.2.3.4.4, REDUCE TO 0.75 FOR SEISMIC DESIGN TENSION WHEN CONCRETE CONTROLS)}$$

$$\text{DEAD LOAD TENSION FACTOR (F}_{DLN}) = 1.00 \text{ (0.75 WHEN ANCHOR IS UNDER SUSTAINED DEAD LOAD TENSION, SECTION 4.1.1 OF ESR)}$$

$$T_{all} = N_{all} = F_{DLN} F_{SCN} N_a / \alpha = 1383 \text{ lbs}$$

$$V_{all} = F_{SCV} V_d / \alpha = 2391 \text{ lbs}$$

GIVEN BOLT FORCES FROM SHEET: 63592-C1.3

$$\text{INPUT HERE } T_{ab} = 1045.90 \text{ lbs}$$

$$V_{ab} = 204.15 \text{ lbs}$$

CHECK COMBINED LOADING (ACI 318 EQN. 17.6.3)

$$\frac{T_{ab}}{T_{all}} + \frac{V_{ab}}{V_{all}} = 0.84 \leq 1.2$$

ANCHOR OKI

ANCHORAGE SUMMARY:

1/2 in DIAMETER ASTM

A 193 Gr B7 CARBON STEEL THREADED ROD W/ A-194 NUT,

4 in MIN. EMBEDMENT,

6 in MIN. EDGE DISTANCE,

8 in MIN. CONCRETE THICKNESS

3000 psi HARDROCK CONCRETE.

INSTALL IN CONCRETE WITH A HAMMER DRILL AND CARBIDE BIT AND

SET WITH HILTI HIT-RE 500 V3 ADHESIVE AS PER THE ICC ESR-3814.

SPECIAL INSPECTION REQUIRED PER SECTION 4.4 OF THE ESR-3814.



JOB NAME:	PACIFIC HIGH SCHOOL POOL HEATER - SURERACK SUPPORT FRAME ANALYSIS	M. W. SAUSSE' & CO., INC.
CUST.:	MAROKO & SHWE, INC.	PREPARED BY: FS
MECH. ENG.:		DATE: 11-Feb-19
MARK:	RAYPAK SURERACK SUPPORT FRAME	SHEET NO.: 63592-C1.6