



ADDENDUM NO. 3

OCTOBER 15, 2021

TO THE CONTRACT DOCUMENTS FOR

F21-05 DEL VALLEJO – SITE IMPROVEMENTS (04-119911) & LUNCH SHELTER (04-120142)

NOTICE TO BIDDERS This Addendum forms a part of the Contract and modifies the original documents. It is intended that all work affected by the following modifications shall conform with related provisions and general conditions of the contract of the original drawings and specifications. Modify the following items wherever appearing in any drawing or sections of the specifications. Acknowledge receipt of Addendum No. 3 in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

1. ADDITIONS AND CLARIFICATIONS

A. The following additions and clarifications are issued to all bidders as information for use in preparing bids:

1. Del Vallejo Site Improvements 04-119911 – Davy Architecture

None

2. Del Vallejo Lunch Shelter 04-120142- Architects Mosher Drew

- a. **RFI # 4** - Response to Harik Construction, Inc. – see attachment
- b. **RFI # 5** - Response to Harik Construction, Inc. – see attachment

3. ATTACHMENTS

RFIs # 4 & 5

END OF ADDENDUM No. 3

04-120142
RFI #4
LUNCH SHELTER

Pre-Bid Clarification Form (For CONTRACTOR's Use during Bid only)

PROJECT NAME:	Del Vallejo MS - Lunch Shelter DSA # 04-120142		
PROJECT NUMBER:	F21-05 Del Vallejo		
TO:	Mr. Tom Bourque	EMAIL:	tomb@mosherdrew.com

DATE:	9/30/2021		
FROM:	Harik Construction Inc.	EMAIL:	Lilah@harikconstruction.com
DOCUMENT/DIVISION NUMBER:	Lunch Shelter	DRAWING NUMBER:	A2.1 and P.C. T-1.0

REQUESTED CLARIFICATION:
<p>RFI # 1</p> <p>1. Please clarify who is responsible to furnish and install the Lunch Shelter including the drilled pier footing for the columns.</p>
RESPONSE TO CLARIFICATION:
<p>Per specification section 01 11 00, 1.03, SUMMARY SCOPE OF WORK, the GC is responsible to furnish and install the Lunch Shelter (including the drilled pier footings for the columns).</p> <p>As a subcontractor under the GC, the shade structure manufacturer shall (at least in the case of the Basis of Design manufacturer, USA Shade & Fabric Structures) manufacture, deliver, and install the shade structure. USA Shade's installation includes the foundations and erection of all shade structure components.</p> <p>Please note, USA Shade will <u>not</u> furnish or install the light fixtures which the Electrical drawings show mounted on the shade structure columns, although USA Shade is amenable to them being installed on their structure. That scope would be by the GC's Electrical Subcontractor.</p> <p>Tom Bourque / Architects Mosher Drew - 9/30/2021</p>

04-120142
RFI #5
LUNCH SHELTER

Pre-Bid Clarification Form (For CONTRACTOR's Use during Bid only)

PROJECT NAME:	Del Vallejo MS - Lunch Shelter DSA # 04-120142		
PROJECT NUMBER:	F21-05 Del Vallejo		
TO:	Mr. Tom Bourque	EMAIL:	tomb@mosherdrew.com

DATE:	9/30/2021		
FROM:	Harik Construction Inc.	EMAIL:	Lilah@harikconstruction.com
DOCUMENT/DIVISION NUMBER:	Lunch Shelter	DRAWING NUMBER:	C001 to C200

REQUESTED CLARIFICATION:
<p>RFI # 2</p> <p>1. Please clarify if there are any SWPPP/Erosion Control Scope Requirements in this project.</p>

RESPONSE TO CLARIFICATION:
<p>Per spec section 015723 1.2 A 2.</p> <p>The contractor will supply the following docs</p> <p>a. Conceptual SWPPP or WPCP, prepared by a Qualified SWPPP Developer (QSD) to minimize the discharge of pollutants in stormwater due to construction activities.</p> <p>b. Notice of Intent (NOI).</p> <p>c. Risk Assessment.</p> <p>d. Conceptual Site Map.</p> <p>e. WDID.</p> <p>The site is less than an acre so a contractor WPCP will need to be provided items b, c and e would not apply</p>

Mike MaGee WSP 9/30/21